



U-FER GROUND

2002 National Electrical Code, Article 250.52 (A) (3)

(Shall be located as close as possible to the electrical panel.)

