BROOMFIELD HEALTH & HUMAN SERVICES
PUBLIC HEALTH & ENVIRONMENT DIVISION
Environmental Health Office
Individual Sewage Disposal Systems

6 Garden Center
Broomfield, CO 80020
720-887-2220
720-887-2229 (Fax)

PERCOLATION TEST RESULT FORM

Hole No.	Hole Depth (in.)	Length of interval (min.)	Water Depth @ Start of Interval (in.)	Water Depth @ End of Interval (in.)	Drop in Level (in.)	Percolation Rate @ Final Interval (min./in.)

Note:

1) Field Notes shall be recorded on this form or in this format; typed copies of field records may be submitted on this form.

2) A four hour test must be conducted unless (a) water remains in the hole after the presoak in which case one 30 min. interval is sufficient, (b) the first 6" of water seeps away in <30 minutes in which case a one-hour test of 6-10 minute time intervals may be used, (c) the test is being conducted in sand (SW or SP) in which case a one-hour test of 6-10 minute time intervals may be used, (d) three successive water level drops do not vary by more than 1/16 inch in which case a two-hour test may be conducted, (e) test is in Dawson Sands, in which case the test must be run a minimum of four hours until the last three successive water level drops vary by less that 1/16 inch.